

CONSTRUCTION NOTES:

1.0 GENERAL

- THE LOCATION OF ALL UNDERGROUND AND ABOVEGROUND UTILITIES AND STRUCTURES IS NOT NECESSARILY SHOWN ON THESE DRAWINGS, AND, WHERE SHOWN, THE ACCURACY OF THE LOCATION OF SUCH UTILITIES AND STRUCTURES IS NOT GUARANTEED. BEFORE STARTING WORK, THE CONTRACTOR SHALL DETERMINE THE EXACT HORIZONTAL AND VERTICAL LOCATION OF ALL SUCH UTILITIES AND STRUCTURES, AND SHALL ASSUME ALL LIABILITY FOR DAMAGE TO THEM. THE CONTRACTOR SHALL
- IMMEDIATELY NOTIFY THE ENGINEER OF ANY CONFLICTS WITH THE EXISTING UTILITIES. ALL AREAS DISTURBED BY THE CONTRACTOR DURING THE CONSTRUCTION OF THE WORKS SHOWN HEREIN SHALL BE RESTORED TO ORIGINAL CONDITION OR BETTER TO THE SATISFACTION OF THE TOWN OF MILTON. ALL GRASS AND VEGETATION COVERED AREAS SHALL BE RESTORED BY PLACING 100mm OF TOPSOIL AND No. 1 NURSERY SOD TO ESTABLISH A GRASS COVER TO THE SATISFACTION OF THE TOWN UNLESS NOTED
- TOWN OF MILTON AND REGION OF HALTON STANDARD DRAWINGS AND OPSD WITH REGIONAL AMENDMENTS FOR SANITARY SEWERS AND WATERMAINS SHALL CONSTITUTE PART OF THE ENGINEERING DESIGN AND CONSTRUCTION CONTRACT. CONTRACTOR TO MAINTAIN CURRENT COPY OF TOWN, REGION AND ONTARIO STANDARDS ON SITE AT ALL TIMES.
- ALTERNATIVE MATERIALS MAY BE ACCEPTABLE, PROVIDED APPROVAL HAS FIRST BEEN OBTAINED FROM THE TOWN AND/OR THE REGIONAL COMMISSIONER OF PUBLIC WORKS.
- NO BLASTING IS PERMITTED.

THAT DEPICT WORKS THAT ARE PROPOSED FOR THIS SITE.

- MANHOLE AND VALVE CHAMBER COVERS ARE TO BE SET FLUSH WITH BASE COURSE ASPHALT AND ADJUSTED TO FINAL GRADE PRIOR TO INSTALLING TOP LIFT OF ASPHALT.
- 1.7 ALL TRENCHES WITHIN EXISTING R.O.W. ARE TO BE BACKFILLED IN ACCORDANCE WITH TOWN OF MILTON REQUIREMENTS
- ALL DIMENSIONS TO BE CHECKED AND VERIFIED ON THE SITE PRIOR TO ANY CONSTRUCTION. ANY DISCREPANCIES ARE TO BE REPORTED TO THE ENGINEER BEFORE PROCEEDING. CONTRACTOR TO PROVIDE SHOP DRAWINGS OF ALL MATERIALS AND PRODUCTS FOR REVIEW BY THE
- ENGINEER PRIOR TO INSTALLATION. 1.10 REFER TO TOWN AND REGION STANDARDS AND SPECIFICATIONS FOR LIST OF APPROVED MANUFACTURERS
- 1.11 ENCROACHMENT ONTO ADJACENT PROPERTIES IS NOT PERMITTED UNLESS OTHERWISE NOTED AND
- INSTRUCTED BY THE ENGINEER. 1.12 THE APPROVAL OF THIS PLAN DOES NOT EXEMPT THE OWNER'S CONTRACTOR FROM OBTAINING AND
- PAYING FOR PERMITS. 1.13 THIS PLAN IS TO BE READ IN CONJUNCTION WITH THE SITE PLAN AND ANY OTHER PLANS OR DRAWINGS
- 1.14 THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL TRAFFIC CONTROL AND SAFETY MEASURES DURING THE CONSTRUCTION PERIOD. INCLUDING THE SUPPLY. INSTALLATION AND REMOVAL OF ALL NECESSARY SIGNAGE, DELINEATORS, MARKERS AND BARRIERS. ALL SIGNS, ETC. SHALL CONFORM TO THE STANDARDS AND SPECIFICATIONS FOR THE TOWN AND THE MTO MANUAL OF UNIFORM TRAFFIC CONTROL DEVICES FOR
- 1.15 THE CONTRACTOR SHALL ENDEAVOR TO PREVENT MUD TRACKING ONTO ADJACENT LANDS AND EXISTING ROADS AND SHALL PROVIDE FOR CLEANUP AT OWN EXPENSE AS DIRECTED BY THE TOWN AND ENGINEER. THE CONTRACTOR SHALL ALSO BE RESPONSIBLE TO CONTROL DUST ON THE PROJECT AND HE SHALL PROVIDE AT OWN EXPENSE DUST CONTROLLING MEASURES AS DIRECTED.
- 1.16 THE CONTRACTOR IS RESPONSIBLE FOR LOCATING AND PROTECTING ALL EXISTING ABOVE AND BELOW GROUND UTILITIES PRIOR TO AND DURING CONSTRUCTION.
- 1.17 ANY UTILITY RELOCATIONS DUE TO THIS DEVELOPMENT TO BE UNDERTAKEN AT THE EXPENSE OF THE 1.18 ALL CONSTRUCTION WORK IS TO BE CARRIED OUT IN ACCORDANCE WITH THE REQUIREMENTS OF THE
- OCCUPATIONAL HEALTH AND SAFETY ACT AND REGULATIONS FOR CONSTRUCTIONS PROJECTS. 1.19 CONSTRUCTION ACCESS SHALL BE CONSTRUCTED PER DETAIL ON THIS PLAN, AND PER TOWN ENTRANCE AND ROAD OCCUPANCY PERMITS, AS REQUIRED.
- 1.20 ALL EXISTING SEWERS ARE TO BE CONFIRMED ON SITE PRIOR TO CONSTRUCTION INCLUDING SEWER INVERTS, MATERIAL TYPE, AND SIZE. ANY DISCREPANCIES SHALL BE REPORTED TO THE ENGINEER.
- 1.21 PRECONSTRUCTION FLUSH AND VIDEO OF EXISTING PRIVATE OR MUNICIPAL SEWERS TO CONFIRM CONDITIONS OF ANY SEWER TIE-INS, TO THE SATISFACTION OF THE ENGINEER/MUNICIPALITY AS
- 1.22 FLUSH AND VIDEO ALL STORM SEWERS UPON INSTALLATION AND PROVIDE THREE (3) PHYSICAL COPIES OF REPORTS AND VIDEOS. THIS INCLUDES MAINLINE SEWERS, LATERALS, LEADS AND SERVICES UP TO THE STUB. THE CCTV INSPECTION TO BE CARRIED OUT AS DETAILED IN OPSS 409. ONE FLUSH AND CCTV VIDEO ROUND IS TO BE COMPLETED PRIOR THE PLACEMENT OF BASE ASPHALT. SECOND ROUND OF FLUSH AND CCTV TO BE COMPLETED AFTER THE PLACEMENT OF BASE ASPHALT. THIRD ROUND OF FLUSH AND CCTV TO BE COMPLETED AFTER THE PLACEMENT OF TOP ASPHALT AND COMPLETION OF ALL LANDSCAPING. THIS ITEM TO ALSO INCLUDE CLEANING OF ALL STRUCTURES.
- 1.23 CONTRACTOR SHALL PROVIDE A DIGITAL AS-BUILT SURVEY OF ALL UNDERGROUND AND ABOVEGROUND WORKS TO THE SATISFACTION OF THE ENGINEER. AS-BUILT INFORMATION TO INCLUDE A FULL TOPOGRAPHIC SURVEY OF THE SITE. THE AS-BUILTS SHOULD INCLUDE BUT IS NOT LIMITED TO: LAYOUT OF ALL SEWERS AND WATERMAIN, INVERTS AND TOP OF COVER/GRATES IN STRUCTURES, HEADWALLS, STORMWATER MANAGEMENT FEATURES, CURBS, LONGITUDINAL AND CROSSFALL SLOPES OF SIDEWALKS, CENTRE LINE OF ROADS AND EDGE OF PAVEMENT TO CHECK CROSSFALLS AND ROAD/PARKING LOT GRADES, HANDICAP RAMPS, ETC. ANY DEVIATIONS FROM THE ORIGINAL DESIGN ARE TO BE INCLUDED IN THE AS-BUILT DRAWINGS. AS-BUILT INFORMATION TO BE SUPPLIED TO CONTRACT ADMINISTRATOR IN BOTH CAD & PDF FORMATS. THE AS-BUILT INFORMATION WILL BE REQUIRED ONCE AT BASE ASPHALT PLACEMENT COMPLETION AND AGAIN AFTER COMPLETION OF TOP ASPHALT AND LANDSCAPING.
- 1.24 THE CONTRACTOR IS TO INCLUDE IN THEIR SCOPE TO CONFIRM CONDITIONS OF ANY WATERMAIN ELEMENTS (HYDRANTS, VALVE BOXES, WATER CHAMBERS, ETC.) A MINIMUM THREE TIE-INS TO EXISTING ABOVE-GROUND VISIBLE PERMANENT ELEMENTS (I.E. EXISTING POLES, CATCHBASINS, ETC.) 1.25 CONTRACTOR TO INSTALL A SEDIMENT FENCE ON THE PERIMETER OF THE PROPERTY AND AT LOCATIONS
- ETERMINED BY THE MANAGER, DEVELOPMENT ENGINEERING, TOWN OF MILTON, PRIOR TO COMMENCEMEN' OF ANY WORKS ON THE SITE. SEDIMENT FENCE TO REMAIN IN PLACE FOR THE DURATION OF THE CONTRACT OR AS DIRECTED BY THE MANAGER, DEVELOPMENT ENGINEERING, TOWN OF MILTON.
- 1.26 SILT CONTROLS ARE TO BE IN PLACE PRIOR TO THE START OF SITE WORKS AND ARE TO BE MAINTAINED FOR THE DURATION OF THE CONSTRUCTION.
- 1.27 PRIOR TO COMMENCEMENT OF ANY WORKS WITHIN THE MUNICIPAL ROAD ALLOWANCE. THE CONTRACTOR IS RESPONSIBLE TO OBTAIN ALL NECESSARY PERMITS FROM THE TOWN OF MILTON, FOR THE PURPOSES OF VEHICULAR ACCESS TO THE PROPERTY, (ENTRANCE PERMIT), AND SERVICING EXCAVATIONS, (ROAD OCCUPANCY PERMIT). WITHIN THE MUNICIPAL RIGHT OF ALLOWANCE. THE CONTRACTOR SHALL ALSO COMPLY WITH ALL CONDITIONS DICTATED BY SUCH PERMITS AT NO EXTRA COST TO THE OWNER. ALL PERMITS AND ASSOCIATED DRAWINGS AND CONDITIONS MUST BE ON-SITE AND AVAILABLE UPON

2.0 STORM SEWERS

- 2.1 ALL STORM SEWERS 450mmø AND SMALLER TO BE PVC SDR-35, ASTM F794, ASTM D1784 OR LATEST
- 2.2 ALL STORM SEWERS 525mmø AND LARGER TO BE CONCRETE PER OPSS 1820 AND OPSS 1821.
- 2.3 BEDDING AND COVER FOR PVC SEWERS (FLEXIBLE PIPE) AS PER OPSD 802.010. 2.4 BEDDING AND COVER FOR CONCRETE SEWERS (RIGID PIPE) AS PER OPSD 802.030
- STORM MANHOLES SHALL BE AS PER OPSD AS SPECIFIED. BENCHING TO SPRINGLINE OF PIPE AS PER OPSD 701.021. FRAME & COVER AS PER OPSD 401.010 TYPE "A". COVERS TO BE EMBOSSED WITH THE
- 2.6 ALL CATCH BASIN MANHOLES AS PER OPSD AS SPECIFIED. FRAMES AND GRATES AS PER OPSD 400.010 WHEN ADJACENT TO CURB & 400.020 IN ALL OTHER CASES.
- ALL MANHOLE AND CATCH BASIN ADJUSTMENTS SHALL BE AS PER OPSD 704.010. MAXIMUM OF THREE (3) UNITS AND 300mm HIGH, WHERE EXCEEDED CAST-IN-PLACE OR PRE-CAST RISER SECTIONS SHALL F PROVIDED
- 2.8 ALL CATCH BASINS SHALL BE AS PER OPSD AS SPECIFIED. FRAMES AND GRATES AS PER OPSD 400.010 WHEN ADJACENT TO CURB & 400.020 IN ALL OTHER CASES. 2.9 ALL CATCH BASIN CONNECTIONS SHALL BE AS PER OPSD 708.010 (RIGID PIPE) AND OPSD 708.030
- 2.10 ALL SEWER SERVICE CONNECTIONS FOR FLEXIBLE PIPE SHALL BE AS PER OPSD 1006.020.
- 2.11 ALL TESTING OF STORM SERVICES TO BE IN ACCORDANCE WITH ONTARIO PROVINCIAL STANDARD
- 2.12 ALL SINGLE CATCH BASIN LEADS TO BE 250mmø AND DOUBLE CATCH BASIN LEADS TO BE 300mmø, UNLESS NOTED OTHERWISE.

3.0 MAINTENANCE & OPERATION OF SEDIMENT CONTROLS

- SEDIMENT FENCE TO BE INSTALLED BY THE CONTRACTOR IN LOCATIONS SHOWN ON PLAN AND AS DIRECTED BY SITE ENGINEER PRIOR TO CONSTRUCTION.
- 3.2 SEDIMENT FENCE MUST BE INSPECTED BY THE CONTRACTOR WEEKLY FOR RIPS OR TEARS, BROKEN
- STAKES, BLOW-OUTS AND ACCUMULATION OF SEDIMENT. 3.3 SEDIMENT FENCE MUST BE INSPECTED BY THE CONTRACTOR FOLLOWING ALL 10MM OR GREATER RAIN STORM EVENT OR AS DIRECTED BY ENGINEER.
- SEDIMENT MUST BE REMOVED BY THE CONTRACTOR FROM SEDIMENT FENCE WHEN ACCUMULATION REACHES 50% OF THE HEIGHT OF FENCE.
- 3.5 ALL SEDIMENT FENCES MUST BE REMOVED BY THE CONTRACTOR ONLY WHEN THE ENTIRE SITE IS STABILIZED AND AS DIRECTED BY THE SITE ENGINEER. 3.6 EXISTING STREET CATCHBASINS AT CONSTRUCTION ENTRANCES TO INCLUDE SILT SACKS, AND INSPECTED
- FOLLOWING ALL 10MM OR GREATER RAIN STORM EVENTS, OR AS DIRECTED BY ENGINEER. 3.7 UPON INSTALLATION OF ALL FUTURE CATCH BASINS AND CATCH BASIN MANHOLES TO INCLUDE SILT SACKS, AND INSPECTED BY THE CONTRACTOR FOLLOWING ALL 10MM OR GREATER RAIN STORM EVENTS, OR AS DIRECTED BY ENGINEER.


4.0 SITE GRADING


- 4.1 ALL GRADING MUST COMPLY WITH THE TOWN OF MILTON STANDARDS UNLESS OTHERWISE NOTED.
- 4.2 ENGINEERED FILL TO BE PLACED IN 300MM THICK LIFTS AND MECHANICALLY COMPACTED TO 100% SPMDD AS RECOMMENDED OR AS APPROVED BY GEOTECHNICAL ENGINEER.
- 4.3 COMPACTION RESULTS AND CERTIFICATION FROM GEOTECHNICAL ENGINEER REQUIRED FOR ALL ENGINEERED
- 4.4 GEOTECHNICAL ENGINEER SHALL ASSESS AND CONFIRM SUITABILITY OF EXISTING INSITU SOILS TO ACCEPT ENGINEERED FILL AND MEET SPECIFICATIONS.
- 4.5 ALL FILLING OPERATIONS TO BE GRADED TO ENSURE SHEET FLOW DRAINAGE TO EXISTING OUTLET AS NOTED ON THE ESC PLAN. THE CONTRACTOR IS RESPONSIBLE FOR ALL REQUIRED TESTING BY THE MUNICIPALITY AND/OR ENGINEER AS APPLICABLE.
- CONTRACTOR TO PROVIDE TOPOGRAPHIC SURVEY AT THE FOLLOWING STAGES FOR REVIEW BY THE ENGINEER: (I) PRE-CONSTRUCTION, (II) AFTER THE COMPLETION OF TOPSOIL STRIPPING, (III) AFTER THE


EROSION & SEDIMENT CONTROL NOTES:

1.0 GENERAL NOTES

- 1.1 ALL CONSTRUCTION EQUIPMENT TO REMAIN ON-SITE FOR THE DURATION OF ALL CONSTRUCTION ACTIVITIES. NO EXTERNAL ACCESS IS REQUIRED.
- 1.2 CONTRACTOR SHALL NOTIFY THE TOWN AND ENGINEER IN WRITING WITHIN 48 HOURS OF COMMENCING ANY SITE WORKS.
- 1.3 CONTRACTOR SHALL NOTIFY TOWN AND ENGINEER IN WRITING OF THE COMPLETION OF ANY CONTROL MEASURES WITHIN 24 HOURS AFTER THEIR INSTALLATIONS.
- 1.4 CONTRACTOR SHALL OBTAIN PERMISSION FROM THE DIRECTOR (ENGINEERING, TOWN OF MILTON), PRIOR TO MODIFYING THE ESC PLAN C101.
- 1.5 CONTRACTOR SHALL MAINTAIN ALL ROAD DRAINAGE SYSTEMS, STORMWATER DRAINAGE SYSTEMS, AND CONTROL MEASURES IDENTIFIED IN THE ESC PLAN C101. 1.6 CONTRACTOR SHALL IMMEDIATELY REPAIR ANY SILTATION OR EROSION DAMAGE TO ADJOINING SURFACES
- AND DRAINAGE-WAYS RESULTING FROM LAND DEVELOPING OR DISTURBING ACTIVITIES. CONTRACTOR SHALL INSPECT THE CONSTRUCTION CONTROL MEASURES AT LEAST ONCE PER WEEK AND AFTER EACH RAINFALL OF 10MM OR GREATER AND MAKE NEEDED REPAIRS.
- 1.8 CONTRACTOR MUST ALLOW EMPLOYEES OF THE TOWN TO ENTER THE SITE FOR THE PURPOSE OF INSPECTING FOR COMPLIANCE WITH THE CONTROL PLAN OR FOR PERFORMING ANY WORK NECESSARY TO BRING THE SITE INTO COMPLIANCE WITH THE CONTROL PLAN.
- 1.9 CONTRACTOR MUST MAINTAIN A PRINTED COPY OF THE ESC PLAN C101 ON THE SITE. 1.10 CONTRACTOR TO REVIEW CONDITIONS OF ALL APPROVALS PRIOR TO CONSTRUCTION.
- 1.11 ALL STOCKPILE SIDE SLOPES TO BE 4:1 MAX. ANY STOCKPILES LEFT UNDISTURBED FOR 30 DAYS ARE TO BE SEEDED WITH NATIVE GRASS
- 1.12 CONTRACTOR TO EROSION AND SEDIMENT CONTROLS AS PER DRAWINGS AND ELSEWHERE AS NOTED BY







- l Flexible and composite pavement shall be placed 5mm above the adjacent edge of gutter 2 When sidewalk is continuously adjacent, the dropped curb at entrances shall be reduced to 75mm
- 3 For slipforming procedure a 5% batter is acceptable.
- 4 For composite pavement the depth of concrete curb shall be adjusted to depth of concrete pavement.
- 5 When tie bars are specified, refer to OPSD 552.010 and 552.020 for details. A Treatment at entrances shall be according to OPSD 351.010.
- B Outlet treatment shall be according to the OPSD 610 Series.
- C The transition from one curb type to another shall be a minimum length of 3.0m, except in conjunction with guide
- rail where it shall be according to the OPSD 900 Series. D All dimensions are in millimetres unless otherwise shown.

CONCRETE BARRIER CURB WITH STANDARD GUTTER

ONTARIO PROVINCIAL STANDARD DRAWING

Nov 2012 Rev 2 - - - - - - - -OPSD 600.040


Dropped curb at entrances Thickness of **←** 150 → sidewalk Finished road surface Note 2 . . . 4 . . . — 250 — Additional width when sidewalk is adjacent to curb


I When sidewalk is continuously adjacent, the dropped curb

- at entrances shall be reduced to 75mm. 2 For slipforming procedure a 5% batter is acceptable.
- A Treatment at entrances shall be according to OPSD 351.010.
- B Outlet treatment shall be according to the OPSD 610 Series. C The transition from one curb type to another shall be
- a minimum length of 3.0m, except in conjunction with guide rail where it shall be according to the OPSD 900 Series.
-) All dimensions are in millimetres unless otherwise shown.

ONTARIO PROVINCIAL STANDARD DRAWING

CONCRETE BARRIER CURB





THIS DRAWING IS THE EXCLUSIVE PROPERTY OF C.F. CRO7IFR &

- WRITTEN AUTHORIZATION FROM THIS OFFICE THE DIGITAL FILES CONTAIN INTELLECTUAL AND DIGITAL DATA PROPERTY THAT IS THE EXCLUSIVE PROPERTY OF C.F. CROZIER & ASSOCIATES INC.
- DATUMS ON SITE AND REPORT ANY DISCREPANCIES OR OMISSIONS TO C.F. CROZIER & ASSOCIATES INC. PRIOR TO CONSTRUCTION. THIS DRAWING IS TO BE READ AND UNDERSTOOD IN CONJUNCTION WITH ALL OTHER PLANS AND DOCUMENTS APPLICABLE TO THIS

DO NOT SCALE DRAWINGS.

- ASSOCIATES INC. AND THE MODIFICATION AND/OR REPRODUCTION OF ANY PART OF THIS DRAWING IS STRICTLY PROHIBITED WITHOUT EVATIONS SHOWN HEREON ARE BASED ON GPS OBSERVATIONS O PERMANENT REFERENCE STATIONS IN THE NAD83 (CSRS-20) COORDINATE SYSTEM WITH HEIGHTS CONVERTED TO ORTHOMETRIC LEVATIONS ON THE CGVD28 DATUM (1978 ADJUSTMENT) WITH GEOID MODEL HTV2.0, AS SUPPLIED BY NATURAL RESOURCES THE CONTRACTOR SHALL VERIEY ALL DIMENSIONS, LEVELS, AND
- TE TBM 1: CUT CROSS ON CONCRETE SIDEWALK, 214.54M. TE TBM 2: CUT CROSS ON CONCRETE SIDEWALK, 213.64M. SURVEY NOTES: ALL EXISTING UNDERGROUND UTILITIES TO BE VERIFIED IN THE FIELD


 THE TOPOGRAPHIC SURVEY WAS COMPLETED BY VAN HARTEN

 BY THE CONTRACTOR PRIOR TO CONSTRUCTION.

 LAND SURVEYORS AND PROFESSIONAL ENGINEERS ON JUNE 5, LAND SURVEYORS AND PROFESSIONAL ENGINEERS ON JUNE 5,

2025, PROJECT NO. 34292-25







FOR REVIEW NOT TO BE USED FOR CONSTRUCTION 8465 BOSTON CHURCH ROAD TOWN OF MILTON

NOTES & DETAILS



2878-7432 ´′M.P.H. /J.K.F M.P.F






NOTES:

A Concrete for benching shall be 30MPa. B When benching is hand-finshed, it shall be given wood float finish, channel shall be given steel trowel finish. C Benching slope and height shall be as specified. D When specified, maintenance holes that are 1200mm in diameter with a uniform channel for 200 or 250mm pi may be prebenched at the manufacturer with standardized benching slope and channel orientation. E All dimensions are nominal.

All dimensions are in millimetres unless otherwise shown. ONTARIO PROVINCIAL STANDARD DRAWING

Nov 2014 Rev 4 MAINTENANCE HOLE BENCHING AND PIPE OPENING ALTERNATIVES OPSD 701.021




Nov 2018 Rev 3

OPSD 1105.010

Note 2


ONTARIO PROVINCIAL STANDARD DRAWING


HYDRANT INSTALLATION




PRECAST CONCRETE CATCH BASIN


600x600mm







P



ASSOCIATES INC. AND THE MODIFICATION AND/OR REPRODUCTION OF ANY PART OF THIS DRAWING IS STRICTLY PROHIBITED WITHOUT WRITTEN AUTHORIZATION FROM THIS OFFICE.
THE DIGITAL FILES CONTAIN INTELLECTUAL AND DIGITAL DATA PROPERTY THAT IS THE EXCLUSIVE PROPERTY OF C.F. CROZIER & ASSOCIATES INC. THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS, LEVELS, AND

DO NOT SCALE DRAWINGS.

THIS DRAWING IS THE EXCLUSIVE PROPERTY OF C.F. CROZIER &


O PERMANENT REFERENCE STATIONS IN THE NAD83 (CSRS-201 COORDINATE SYSTEM WITH HEIGHTS CONVERTED TO ORTHOMETRIC ELEVATIONS ON THE CGVD28 DATUM (1978 ADJUSTMENT) WITH DATUMS ON SITE AND REPORT ANY DISCREPANCIES OR OMISSIONS <u>SITE BENCHMARKS:</u> TO C.F. CROZIER & ASSOCIATES INC. PRIOR TO CONSTRUCTION. THIS DRAWING IS TO BE READ AND UNDERSTOOD IN CONJUNCTION WITH ALL OTHER PLANS AND DOCUMENTS APPLICABLE TO THIS


GEOID MODEL HTV2.0, AS SUPPLIED BY NATURAL RESOURCES TE TBM 1: CUT CROSS ON CONCRETE SIDEWALK, 214.54M. TE TBM 2: CUT CROSS ON CONCRETE SIDEWALK, 213.64M. SURVEY NOTES: ALL EXISTING UNDERGROUND UTILITIES TO BE VERIFIED IN THE FIELD


BY THE CONTRACTOR PRIOR TO CONSTRUCTION.

THE TOPOGRAPHIC SURVEY WAS COMPLETED BY VAN HARTEN
LAND SURVEYORS AND PROFESSIONAL ENGINEERS ON JUNE 5, 2025. PROJECT NO. 34292-25

LEVATIONS SHOWN HEREON ARE BASED ON GPS OBSERVATIONS







8465 BOSTON CHURCH ROAD TOWN OF MILTON

NOTES & DETAILS

OPSD 705.010

CONSULTING ENGINEERS

°ject 2878-7432 M.P.H. ^{''}M.P.H./J.K.F